



# DRAFT INTERNATIONAL STANDARD ISO/DIS 3556-1.2

ISO/TC 112/SC 3

Secretariat: GOST

Voting begins on  
1992-05-14

Voting terminates on  
1992-11-14

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION - МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ - ORGANISATION INTERNATIONALE DE NORMALISATION

ANSI Internat Doc Sec

## Sputter-ion pumps — Measurement of performance characteristics —

### Part 1:

Pumps with a volume rate of flow greater than 10 l/s

*Pompes ioniques à pulvérisation — Mesurage des caractéristiques de fonctionnement —*

*Partie 1: Pompes avec débit de pompage supérieur à 10 l/s*

doc. number	date ready
Rev Ltr	1
Revol	2
Sent to:	1
	2
	3
	4
	5
	6
	7
	8
	9
	10
	11
	12
	13
	14
	15
	16
	17
	18
	19
	20
	21
	22
	23
	24
	25
	26
	27
	28
	29
	30
	31
	32
	33
	34
	35
	36
	37
	38
	39
	40
	41
	42
	43
	44
	45
	46
	47
	48
	49
	50
	51
	52
	53
	54
	55
	56
	57
	58
	59
	60
	61
	62
	63
	64
	65
	66
	67
	68
	69
	70
	71
	72
	73
	74
	75
	76
	77
	78
	79
	80
	81
	82
	83
	84
	85
	86
	87
	88
	89
	90
	91
	92
	93
	94
	95
	96
	97
	98
	99
	100
	101
	102
	103
	104
	105
	106
	107
	108
	109
	110
	111
	112
	113
	114
	115
	116
	117
	118
	119
	120
	121
	122
	123
	124
	125
	126
	127
	128
	129
	130
	131
	132
	133
	134
	135
	136
	137
	138
	139
	140
	141
	142
	143
	144
	145
	146
	147
	148
	149
	150
	151
	152
	153
	154
	155
	156
	157
	158
	159
	160
	161
	162
	163
	164
	165
	166
	167
	168
	169
	170
	171
	172
	173
	174
	175
	176
	177
	178
	179
	180
	181
	182
	183
	184
	185
	186
	187
	188
	189
	190
	191
	192
	193
	194
	195
	196
	197
	198
	199
	200
	201
	202
	203
	204
	205
	206
	207
	208
	209
	210
	211
	212
	213
	214
	215
	216
	217
	218
	219
	220
	221
	222
	223
	224
	225
	226
	227
	228
	229
	230
	231
	232
	233
	234
	235
	236
	237
	238
	239
	240
	241
	242
	243
	244
	245
	246
	247
	248
	249
	250
	251
	252
	253
	254
	255
	256
	257
	258
	259
	260
	261
	262
	263
	264
	265
	266
	267
	268
	269
	270
	271
	272
	273
	274
	275
	276
	277
	278
	279
	280
	281
	282
	283
	284
	285
	286
	287
	288
	289
	290
	291
	292
	293
	294
	295
	296
	297
	298
	299
	300
	301
	302
	303
	304
	305
	306
	307
	308
	309
	310
	311
	312
	313
	314
	315
	316
	317
	318
	319
	320
	321
	322
	323
	324
	325
	326
	327
	328
	329
	330
	331
	332
	333
	334
	335
	336
	337
	338
	339
	340
	341
	342
	343
	344
	345
	346
	347
	348
	349
	350
	351
	352
	353
	354
	355
	356
	357
	358
	359
	360
	361
	362
	363
	364
	365
	366
	367
	368
	369
	370
	371
	372
	373
	374
	375
	376
	377
	378
	379
	380
	381
	382
	383
	384
	385
	386
	387
	388
	389
	390
	391
	392
	393
	394
	395
	396
	397
	398
	399
	400
	401
	402
	403
	404
	405
	406
	407
	408
	409
	410
	411
	412
	413
	414
	415
	416
	417
	418
	419
	420
	421
	422
	423
	424
	425
	426
	427
	428
	429
	430
	431
	432
	433
	434
	435
	436
	437
	438
	439
	440
	441
	442
	443
	444
	445
	446
	447
	448
	449
	450
	451
	452
	453
	454
	455
	456
	457
	458
	459
	460
	461
	462
	463
	464
	465
	466
	467
	468
	469
	470
	471
	472
	473
	474
	475
	476
	477
	478
	479
	480
	481
	482
	483
	484
	485
	486
	487
	488
	489
	490
	491
	492
	493
	494
	495
	496
	497
	498
	499
	500
	501
	502
	503
	504
	505
	506
	507
	508
	509
	510
	511
	512
	513
	514
	515
	516
	517
	518
	519
	520
	521
	522
	523
	524
	525
	526
	527
	528
	529
	530
	531
	532
	533
	534
	535
	536
	537
	538
	539
	540
	541
	542
	543
	544
	545
	546
	547
	548
	549
	550
	551
	552
	553
	554
	555
	556
	557
	558
	559
	560
	561
	562
	563
	564
	565
	566
	567
	568
	569
	570
	571
	572
	573
	574
	575
	576
	577
	578
	579
	580
	581
	582
	583
	584
	585
	586
	587
	588
	589
	590
	591
	592
	593
	594
	595
	596
	597
	598
	599
	600
	601
	602
	603
	604
	605
	606
	607
	608
	609
	610
	611
	612
	613
	614
	615
	616
	617
	618
	619
	620
	621
	622
	623
	624
	625
	626
	627
	628
	629
	630
	631
	632
	633
	634
	635
	636
	637
	638
	639
	640
	641
	642
	643
	644
	645
	646
	647
	648
	649
	650
	651
	652
	653
	654
	655
	656
	657
	658
	659
	660
	661
	662
	663
	664
	665
	666
	667
	668
	66

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75% of the member bodies casting a vote.

International Standard ISO 3556-1 was prepared by Technical Committee ISO/TC 112, Vacuum technology, Sub-Committee SC 3, *Measurement of the performance characteristics of vacuum pumps*.

ISO 3556 consists of the following parts, under the general title *Sputter-ion pumps — Measurement of performance characteristics*:

- Part 1: *Pumps with a volume rate of flow greater than 10 l/s*

## Introduction

The purpose of this International Standard is to ensure that measurements of the performance characteristics of sputter-ion pumps are, as far as possible, carried out by uniform procedures and under uniform conditions. It is hoped that, as a result, measurements conducted by different manufacturers or in different laboratories, and statements of performance quoted in manufacturers' literature, will be on a properly comparable basis to the benefit of both user and manufacturer.

It is envisaged that ISO 3556 will, in due course, deal comprehensively with the measurement of the performance of the main types of sputter-ion pumps. In order, however, that useful agreements of more restricted scope may be implemented with the least possible delay, it is intended to publish this International Standard in parts.



## Sputter-ion pumps — Measurement of performance characteristics —

### Part 1: Pumps with a volume rate of flow greater than 10 l/s

#### 1 Scope

This part of ISO 3556 specifies methods of measuring the performance characteristics of sputter-ion pumps of which the volume rate of flow (pumping speed) is greater than 10 l/s. It concerns methods of measuring the following characteristics:

- the ultimate total pressure obtained within a test dome of specified form and dimensions;
- the relation between the volume rate of flow for nitrogen and the pressure, after stabilization of the pump with nitrogen;
- the relation between the volume rate of flow and the pressure after subjecting the pump to a regenerative bake-out procedure.

The range of pressures for the determination of the volume rate of flow should be between at least  $1.0 \times 10^{-3}$  Pa<sup>1)</sup> and  $1.0 \times 10^{-6}$  Pa.

It is to be expected that new pumps may deteriorate in time because during their life they may be subjected to unknown gas loads which will bring about irreversible changes in performance. The tests recommended are therefore for new pumps. In the case of used pumps, the tests will enable performance comparisons to be made provided that they are conducted under the vacuum conditions described below.

#### 2 Definitions

For the purposes of this part of ISO 3556, the following definitions apply.

1)  $133 \text{ Pa} = 1 \text{ Torr} = 1.33 \text{ mbar}$ ;  $1 \text{ Pa} = 7.5 \times 10^{-3} \text{ Torr} = 1 \times 10^{-2} \text{ mbar}$

**2.1 volume rate of flow (pumping speed),  $S$ :** Under ideal conditions, the volume of gas which flows in unit time through the pump inlet. For practical purposes, however, the volume rate of flow of a given pump for a given gas is, by convention, taken to be the quotient of the throughput ( $Q$ ) of that gas and the equilibrium pressure ( $p$ ) at a specified position in a given test dome and under specified conditions of operation. Thus  $S = Q/p$ .

The unit adopted for the volume rate of flow is litre per second (l/s).

**2.2 test dome (test header):** A chamber of specified form and dimensions attached to the inlet of the pump through which a measured flow of gas may be admitted to the pump, and which is equipped with means of pressure measurement.

A test dome for the determination of ultimate total pressure is described in 3.4 and a test dome for the determination of volume rate of flow in 3.5.

**2.3 ultimate pressure:** The limiting pressure approached asymptotically in the dome, with the gas inlet valve closed and the pump in normal operation following the regenerative bake-out as described in 4.1.

#### 3 Apparatus and test gas

##### 3.1 General

All total pressures shall be quoted as equivalent nitrogen pressures. An adequate hot-cathode ionization gauge shall be used for the measurement of total pressure in the range  $4.0 \times 10^{-2}$  Pa to

$1.0 \times 10^{-8}$  Pa. The ionization gauges used shall be calibrated with nitrogen. The calibration of the ionization gauges is liable to change and so the calibration shall be checked periodically.

### 3.2 Hot-cathode ionization gauges

Two hot-cathode ionization gauges are required. In the region of pressure concerned, these gauges shall have a known calibration curve and shall not have an error in pressure reading exceeding  $\pm 10\%$ . The magnetic flux density in the vicinity of these gauges due to stray flux from the magnet of the sputter-ion pump shall be at a sufficiently low level to ensure that the sensitivity of the gauges is not affected by more than  $\pm 3\%$ .

### 3.3 Residual gas analyser

A mass spectrometer used as a residual gas analyser (RGA) may be fitted to the test dome used for the measurement of the volume rate of flow of the pump. Whilst this RGA is not used in arriving at the specification of performance, it is a valuable facility for leak detection of the test system and for the study of inert gas partial pressures, hydrogen desorption and possible hydrocarbon contamination. The use of an RGA is not recommended in the ultimate pressure measurements, however, because it may give a sufficient outgassing load to limit the achievable lowest ultimate pressure.

### 3.4 Test dome for determination of ultimate total pressure (see figure 1)

The test dome shall be of circular cross-section and of inside diameter  $D$ . For large sputter-ion pumps of inlet diameter of 100 mm or greater, the inside diameter  $D$  shall be equal to that of the inlet mouth of the pump to within  $\pm 1.5$  mm for pumps of up to 300 mm inlet diameter and to within  $\pm 3.0$  mm for pumps of inlet diameter greater than 300 mm. For sputter-ion pumps of inlet diameter less than 100 mm, the inside diameter of the test dome shall be 100 mm, irrespective of the pump size. The height of this cylindrical test dome shall be  $3 D/2$ .

The top of the test dome shall be flat. Gaskets between the dome and the flange at the inlet of the sputter-ion pump shall be as recommended by the manufacturer. The dome shall be able to withstand baking under vacuum to  $400^{\circ}\text{C}$ , and is to be supplied with piping to a bakeable closure valve for connection to a roughing pump.

The axis of the piping to the ionization gauge attached to the test dome shall project perpendicularly outwards from the wall of the dome and be at height  $D/2$  above the base of the dome flange. This piping shall contain a right-angle bend upwards to the ver-

tically mounted gauge and shall have a conductance for nitrogen of more than 10 l/s.

### 3.5 Test dome for determination of volume rate of flow (see figure 2)

The test dome shall be of circular cross-section and of inside diameter  $D$ . For large sputter-ion pumps of inlet diameter of 100 mm or greater, the inside diameter  $D$  shall be equal to that of the inlet mouth of the pump to within  $\pm 1.5$  mm for pumps of up to 300 mm inlet diameter and to within  $\pm 3.0$  mm for pumps of inlet diameter greater than 300 mm. For sputter-ion pumps of inlet diameter less than 100 mm, the inside diameter of the test dome shall be 100 mm, irrespective of the pump size.

The total height of this cylindrical test dome shall be  $3 D$ , and it shall have at a height of  $3 D/2$  above the bottom flange of the dome, a thin flat metal plate furnished with a central circular orifice  $O$  of diameter  $d$  and thickness  $a$ . The relation  $a/d$  shall be less than  $0.1 D$  for sputter-ion pumps of inlet diameter equal to or greater than 100 mm.

For pumps with an internal diameter of less than 100 mm, the diameter of the orifice is selected in relation to the expected nominal pump volume rate of flow of such that the indicated pressure ratio in the two sections X and Y of the test dome lies in the range between 5 and 100.

The upper section Y of this dome shall have two cylindrical tubes each projecting perpendicularly outwards from the dome wall. One of these tubes has its axis at a height  $D/2$  above the plane of the plate containing the central orifice, and contains a right-angle bend upwards to the vertically mounted gauge at  $P_1$  and shall have a conductance for nitrogen of more than 10 l/s.

The other tube has a gas inlet containing a right-angle bend and which terminates along the central axis of the dome with its exit at a distance  $D/2$  below the flat top of the dome. This gas inlet tube is furnished at its entrance with a bakeable control valve.

The lower section X of the test dome has three cylindrical tubes, each projecting perpendicularly outwards from the dome wall and each with its axis at a height  $D/2$  above the bottom flange of the dome. One of these tubes is connected to the residual gas analyser (RGA) and the second to a bakeable valve; the third contains a right-angle bend upwards to the vertically mounted gauge at  $P_2$  and shall have a conductance of more than 10 l/s.

### 3.6 Test gas

The test gas shall be nitrogen of purity 99.6 % or higher.

## 4 Procedure

### 4.1 Measurement of ultimate total pressure

First undertake a regenerative bake-out procedure.

With the test dome (3.4) mounted on its inlet flange, evacuate the sputter-ion pump by means of a suitable roughing pump to below the recommended starting pressure and check for leaks. Where necessary, precautions shall be taken by suitable trapping to prevent the ingress into the sputter-ion pump of fluid vapours from the roughing pump.

With the roughing pump in operation, bake the sputter-ion pump and the test dome for at least 4 h at a temperature of 300 °C.

Operate the sputter-ion pump with its normal power supply unit. Isolate the roughing pump by closure of the bakeable valve, and bake the sputter-ion pump and test dome for an additional period of 10 h at a temperature of 300 °C. If the pressure during this bake-out rises above  $5 \times 10^{-2}$  Pa due to a large degassing load, switch off the oven heater until the pressure falls again to about  $1 \times 10^{-3}$  Pa and then switch on again.

Degas the electrodes of the ionization gauge by electron bombardment or another heating process following the procedure recommended by the manufacturer of the gauge. Undertake this degassing during the bake-out, again at the end of the bake-out period, and additionally at least after every 24 h period.

Stop the bake-out but leave the pump in operation. Allow the test dome to cool until it is at a temperature between 15 °C and 25 °C. This temperature shall be maintained within  $\pm 3$  °C for a subsequent period of 48 h. The pressure measured at this time is the ultimate pressure provided that there are no significant variations in its value.

Note the values of the voltage applied to the pump and the current through the pump at the specific pressure. The maximum and minimum ambient temperature prevailing should also be recorded.

### 4.2 Measurement of rate of flow of gas during determination of volume rate of flow

Install the test dome for the volume rate of flow determination (3.5) above the sputter-ion pump.

The gas inlet to the upper section Y of the test dome (see figure 2) is via a bakeable control valve to establish within Y a pressure  $p_1$  as measured by the ionization gauge in position P<sub>1</sub>, whilst the pressure  $p_2$  obtained within the lower section X is measured by an identical gauge in position P<sub>2</sub>.

The throughout,  $Q$ , of the pump into the section Y of the test dome is determined (taking into account the appropriate Clauising factor correction for the thickness-to-diameter ratio of the orifice used) by the following equation:

$$Q = C(p_1 - p_2) \quad \dots (1)$$

where  $C$  is the calculated conductance for nitrogen at the orifice O.

The maximum value of the pressure  $p_1$ , in pascals, is

$$p_{1, \max} = \left( \frac{5 \times 10^{-1}}{d} \right)$$

where  $d$  is the diameter, in millimetres, of the orifice O, to ensure that  $C$  is a true molecular conductance.

From the definition of the volume rate of flow of the pump,  $S$ , it follows that

$$S = \frac{Q}{p_2} \quad \dots (2)$$

Substitution from equation (1) into equation (2) gives

$$S = C \left( \frac{p_1 - p_2}{p_2} \right) = C \left( \frac{p_1}{p_2} - 1 \right) \quad \dots (3)$$

The orifice conductance may be calculated using the formula

$$C = \sqrt{\frac{R T \pi}{32 M}} \times \frac{1}{1 + \frac{a}{d}} d^2 \quad \dots (4)$$

where

$R$  is the ideal gas constant, in joules per mole kelvin;

$T$  is the thermodynamic temperature, in kelvins;

$M$  is the molar mass of the gas, in kilograms per mole;

$a$  is the thickness of orifice plate, in metres;

$d$  is the orifice diameter, in metres;

$C$  is the conductance, in litres per second ( $C = 10^3$  l/s).

In equation (4),  $R = 8,314$  J/(mol K),  $T = 299$  K(20 °C) and  $M_{N_2} = 28 \times 10^{-3}$  kg/mol.

Therefore, for nitrogen at 20 °C

$$C_{N_2} = 92,368 \frac{d^2}{1 + \frac{a}{d}} \text{ l/s}$$

It is recommended to accept that

$$C = \frac{S}{10} \quad \dots (5)$$

The orifice conductance may be calculated using equations (4) and (5) and the values given for  $R$ ,  $T$  and  $M$ .

#### 4.3 Determination of rate of flow of the pump after stabilization

Install the test dome for determination of the pumping volume rate of flow (3.5) above the sputter-ion pump. First undertake the regenerative bake-out procedure as required for the measurement of ultimate pressure (see 3.1).

Establish the equilibrium total pressure in the test dome and measure it at position  $P_2$ .

Then pump a total quantity of nitrogen which is in excess of  $4S$  l/s, where  $S$  is the nominal volume rate of flow in litres per second. This quantity of nitrogen is needed to stabilize the pump.

After pumping this quantity of nitrogen, allow the pump to reach its equilibrium pressure without bake-out. This pressure shall not exceed 0.2 of the lowest pressure at which the volume rate of flow shall be measured.

Then increase the pressure in steps (three per decade) by admitting nitrogen to the test dome to establish the measured pressure  $p_2$  over the range from the lowest value up to  $1 \times 10^{-3}$  Pa. The pressure  $p_1$  in the section Y of the test dome above the orifice (see figure 2) shall not exceed  $p_{1,\max}$  otherwise molecular flow through the orifice cannot be assumed.

The pressure should then be decreased in steps to check for any variation in speed measurements for at least a third of the number of previously measured points. It is necessary to wait for a considerable period of time (sometimes a few hours) between pressure settings to ensure that equilibrium conditions prevail. For this purpose, equilibrium conditions are said to have been established when any increasing or decreasing trend of the measured volume rate of flow or of the indicated pressure does not exceed  $\pm 5\%$  in a period of time of the order of 1 h.

#### 4.4 Test for reversibility of the regenerative procedure following stabilization

Repeat the regenerative bake-out after measure-

ment of the volume rate of flow and measure the equilibrium pressure. This value shall not be more than 2 to 3 times that found just prior to the regenerated volume rate of flow measurements. This procedure is to establish that the performance of the pump has not been significantly modified by the stabilization process.

#### 4.5 Determination of the regenerated volume rate of flow for nitrogen

Carry out the regenerative bake-out procedure as required for the measurement of ultimate pressure with the test dome for the volume rate of flow determination installed above the sputter-ion pump.

Then repeat the procedure described in 4.3. The volume rate of flow measurements should be carried out for at least a third of the number of the previously measured points.

### 5 Test results

The ultimate pressure shall be recorded in pascals.

The saturated volume rate of flow as a function of pressure shall be recorded as a graph of volume rate of flow (linear or logarithmic scale) in litres per second against pressure (logarithmic scale).

The nominal volume rate of flow is quoted as the maximum volume rate of flow obtained on the stabilized volume rate of flow characteristics; it is used as a brief specification of the pump. The pressure at which the nominal volume rate of flow is quoted shall be stated.

The regenerated volume rate of flow against pressure shall be recorded as a graph of volume rate of flow (linear or logarithmic scale) in litres per second against pressure (logarithmic scale).

### 6 Test report

The reported results of ultimate total pressure and of volume rate of flow against pressure characteristics shall include a statement of the maximum and minimum ambient temperature in the immediate vicinity of the test dome.

If a residual gas analyser is used, the mass spectrum of the residual gases during the test shall be given.




Figure 1 — Test dome for measurement of ultimate pressure




Figure 2 — Test dome for measurement of volume rate of flow



<b>EXPLANATORY REPORT</b>		ISO/DIS 3556/1.2
<b>RAPPORT EXPLICATIF</b>		
will supersede: ISO/CD 3556/1		
remplacera:		
ISO/TC 112sc 3	Secretariat	GOST

This form should be sent to the ISO Central Secretariat, together with the English and French versions of the committee draft, by the secretariat of the technical committee or sub-committee concerned (see 2.4.6 of part 1 of the IEC/ISO Directives)

Ce formulaire doit être envoyé au Secrétariat central de l'ISO en même temps que les versions anglaise et française du projet de comité, par le secrétariat du comité technique ou du sous-comité concerné (voir 2.4.6 de la partie 1 des Directives CEI/ISO)

The accompanying document is submitted for circulation to member body vote as a DIS, following consensus of the P-members of the committee obtained

Le document ci-joint est soumis, pour diffusion comme DIS, au vote comité membre, suite au consensus des membres (P) du comité obtenu

on  
le 19.75-05-21

at the meeting of TC..... /SC.....: see resolution No. ....  
à la réunion du ..... /SC.....: voir résolution No. ....

by postal ballot initiated on 19.74-11-21  
par un vote par correspondance démarré le 19.74-11-21

P-members in favour:  
Membres (P) approuvant le projet:

P-members voting against:  
Membres (P) désapprouvant:

P-members abstaining:  
Membres (P) s'abstenant:

P-members who did not vote:  
Membres (P) n'ayant pas voté:

Remarks/Remarques

ISO/DIS 3556/1 was balloted in 1975 and approved by the required majority. However, it was not returned to the Central Secretariat in due time evidently because of the intention of the BSI Secretariat to relinquish its duties which indeed occurred in 1976. Since then the development of DIS 3556/1 was actually discontinued.

The SC 3 Secretariat (GOST) has reexamined the document and now submits the revised English and French versions for the second combined vote.

I hereby confirm that this draft meets the requirements of part 3 of the IEC/ISO Directives  
Je confirme que ce projet satisfait aux prescriptions de la partie 3 des Directives CEI/ISO

Date 31-11-22

Name and signature of the secretary  
Nom et signature du secrétaire

*Helene (N. Levina)*